

Town of Montague Invitation to Bid
Carnegie Library Basement Rehabilitation Project
Addendum #4

Issued: 8/26/2024

Building Electrical Load – In response to a verbal question raised, it is required that each bidder perform an electrical load calculation for the HVAC equipment included in their bid. Using this calculation, please specify whether the current 200 amp electrical panel is sufficient, or if replacement with a 400 amp panel is required. If the upgrade is necessary, please provide a cost estimate for this item on the **updated bid form** (page 17-18 of the IFB). If the upgrade is not necessary, simply write “n/a” on the line provided in the updated bid form.

Bid Opening & Bid Submission Deadline – As a result of the requirements from this addendum, the deadline for submission of bids has been extended to **1:00PM on Wednesday, September 4, 2024**. At that time, bids will be opened and publicly read in the **Town Hall Annex Meeting Room** located at 1 Avenue A, Turners Falls, MA.

Deadline for Questions – The deadline to submit written questions to the Project Manager has been extended to August 28, 2024 at 3PM.