

Selectboard Executive Session
Town Hall Annex, 1 Avenue A, Turners Falls, MA
Monday, April 10, 2023
6:00 PM

RE: Executive Session in accordance with G.L. c. 30A, §21(a)(6), to consider the possible purchase, exchange, taking, lease or value of real property - FirstLight Power, votes may be taken

Present: Selectboard Richard Kuklewicz, Christopher Boutwell and Matt Lord, Town Administrator Steve Ellis

Documents:

- Appendix A: Draft License Articles – Turners Falls Hydroelectric Project
- Appendix B: Draft License Articles – Northfield Mountain Pumped Storage Project
- Appendix C: Measures Agreed to Among the Parties but not to be included in New Project License
- Appendix D: Authorized Representatives of the Parties

Kuklewicz opens the meeting at 6:00 PM.

- Ellis reviewed the last FERC settlement meeting with the Selectboard
- Is new section 3.2 trumping 4.3.1? Lord says this recognizes potential conflict and despite the conflict, we maintain the right to make our case against erosion in the future.
- In that context, is it okay to allow the impoundment level to not be called out as a reserved right? Theoretically, yes. Would need to show the hard science to prove that impoundment levels impact erosion, contradicting FirstLight studies.
- Does the Board agree in principle to move forward with the recreational agreement, pending public input? Do public input over two meetings to allow consideration.
- Discussion what public process we'd want. It would be a chance to hear people's thoughts on the recreational agreement and relationship to fish and flows.

Kuklewicz makes the motion to indicate, through Steve Ellis, Town Administrator, the willingness to consider the recreation agreement as proposed with a decision pending a public meeting and discussion. Seconded by Lord, approved unanimously. Boutwell – Aye, Kuklewicz – Aye, Lord – Aye

Boutwell makes the motion to adjourn the executive session at 6:20 PM. Seconded by Lord, approved unanimously. Boutwell – Aye, Kuklewicz – Aye, Lord – Aye

Approved:

✓ Richard J. Kuklewicz

Release to the Public:

✓ Yes

 Not Yet

7/9/25 Date

Date Released to the Public:

7/9/25

**Turners Falls Hydroelectric Project
(FERC Project Number 1889)**

Bald Eagle Protection Plan



JANUARY 2023

Article A340. Fishway Operating Periods¹

The Licensee shall operate the fishways during the following periods:

Upstream eel passage	May 1 to November 15
Upstream anadromous	April 4 to July 15
Downstream passage	April 4 to November 15

¹Future refinement of the timing on an annual or permanent basis may be made by the MDFW, NMFS, and USFWS based on new information and after consultation with the Licensee.

Article A350. Fish Passage Facilities Operation and Maintenance Plan

The Licensee shall develop and implement a Fish Passage Facilities Operations and Maintenance Plan (FOMP). The FOMP shall detail how and when the fishways will be operated and describe routine maintenance activities that will occur both during and outside of the fish passage season. The FOMP will include a provision to provide annual fishway Operation and Maintenance (O&M) reports that summarize the status of the fish passage facilities, identify needed repairs or equipment replacement, etc. The O&M report shall be submitted to the MDFW, NMFS, and USFWS by January 31 annually. The FOMP shall be developed in consultation with and require approval by the MDFW, NMFS, and USFWS prior to submitting the final FOMP to the FERC for approval.

The FOMP shall be completed no later than 6 months after license issuance for the interim upstream eel passage which will be placed into service within 1 year of license issuance per Article A300, and for existing fish passage facilities (i.e., Cabot downstream fish bypass; Cabot Ladder; Spillway Ladder; and Gatehouse Ladder). Thereafter, the same FOMP shall be amended by the Licensee within 6 months prior to the following:

- Any fish passage structures are placed into service, as outlined in the schedule in Article A300;
- Any AMM's are placed into service, as outlined in the schedule in Articles A320 and A330; and,
- Any operational or facilities modifications resulting from new information obtained from operation of the fish passage facilities pursuant to the annual O&M reports.

FOMP provisions dealing with facilities that are decommissioned over the term of the license may be dropped from revisions of the FOMP after decommissioning.

Article A400. Bald Eagle Protection Plan

The Licensee shall implement the Bald Eagle Protection Plan dated January 2023.

Article A410. Bat Protection Measures

The Licensee shall implement the following measures to protect state or federally listed bat habitat: (1) avoid cutting trees equal to or greater than 3 inches in diameter at breast height within the Turners Falls Project boundary from April 1 through October 31, unless they pose an immediate threat to human life or property (hazard trees); and (2) where non-hazard trees need to be removed, only remove non-hazard trees between November 1 and March 31.

Tier 2	Adaptive Management Measure (if needed)	Schedule
<u>Cabot Tailrace Node</u>	<ul style="list-style-type: none"> Install a behavioral barrier near the Cabot Station tailrace to guide fish upstream for passage at the Turners Falls Dam. If this AMM is implemented, then the Total Minimum Bypass Flow below Station No. 1 (Article A120) will be reduced from 6,500 cfs to 4,500 cfs (Tier 1 AMM) from June 1 to June 15 for the period of testing the Tier 2 measures. At the end of Tier 2 testing (and provided that the 6,500 cfs extension is not needed to significantly improve passage efficiency or time-to-pass at Rawson Island) either the increased flow of 6,500 cfs (June 1 to June 15) will be implemented or the behavioral barrier but not both unless it is demonstrated that both are needed to make a substantial improvement in passage efficiency or time-to-pass. 	Time Needed to Implement AMM(s): Year 15-16 Shakedown: Year 17 Years of Post AMM Effectiveness Testing: Years 18-19
<u>Rawson Island Node</u>	<ul style="list-style-type: none"> If it is determined that the river channel adjacent to Rawson Island is inhibiting upstream fish passage, then constructing a zone of passage is an AMM. Prior to conducting any work associated with this AMM, the Licensee shall consult MDFW, NMFS, USFWS, recreational boating and Tribal interests and the Massachusetts Natural Heritage and Endangered Species Program (NHESP) on the design of the zone of passage. If the zone of passage is constructed, then the Total Minimum Bypass Flow below Station No. 1 will be reduced from 6,500 cfs to 4,500 cfs (Tier 1 AMM) from June 1 to June 15 for the period of testing the Tier 2 measures. At the end of Tier 2 testing (and provided that the 6,500 cfs extension is not needed to significantly improve passage efficiency or time-to-pass at Rawson Island) the 6,500 cfs will be reduced back to 4,500 cfs. 	
<u>Station No. 1 Node</u>	<ul style="list-style-type: none"> Install a behavioral barrier near the Station No. 1 tailrace to guide fish upstream for passage at the Turners Falls Dam. If this AMM is implemented, then the Turners Falls Dam Spill/Sum of Fall River, Turners Falls Hydro, LLC, Milton Hilton, LLL and Station No. 1 flow split will be returned to the 67%/33%, respectively, from April 1 to June 30. At the end of Tier 2 testing, either the increased Turners Falls Dam Minimum Flow component of the flow split used in Tier 1 will be implemented or the behavioral barrier but not both unless it is demonstrated that both are needed to make a substantial improvement in passage efficiency or time to pass. 	
<u>Turners Falls Dam/Fish Lift Node</u>	<ul style="list-style-type: none"> Internal structural modifications to improve hydraulics for fish movement, as necessary. 	

Upstream Adaptive Management Measures- Tier 1 and 2

Tier 1	Adaptive Management Measure (if needed)	Schedule
Cabot Tailrace and Rawson Island Nodes	<p>• Upon license issuance, the Total Minimum Bypass Flow below Station No. 1 from June 1 to June 15 is 4,500 cfs (see Article A120). This AMM includes increasing the Total Minimum Bypass Flow below Station No. 1 from June 1 to June 15 to 6,500 cfs until 90% of the American Shad run enter the Spillway Lift, upon which the Total Minimum Bypass Flow below Station No. 1 will revert to 4,500 cfs.</p> <p>If this adaptive management measure is enacted and after two years of effectiveness testing, it improves the fish passage efficiency and time-to-pass goals, this change may be implemented throughout the remainder of the license, subject to other adaptive management measures. However, even after this change, the 6,500 cfs will revert to 4,500 cfs when 90% of the adult American Shad run enter the Spillway Lift before or within the June 1 to 15 period. The indicator as to when the 90% of the adult American Shad run passes will be determined using a predictive model to be developed by the Licensee in consultation with MDFW, NMFS, and USFWS. The Licensee shall file with the Commission the predictive model results within 6 months of license issuance and it will be updated and/or refined with data collected over intervening years.</p> <p>If this change is implemented, from June 1 to June 15, the Minimum Flow below the Turners Falls Dam (Article A110) must be 4,290 cfs or the NRF, whichever is less; and the Total Minimum Bypass Flow below Station No. 1 (Article A120) must be 6,500 cfs or the NRF, whichever is less.</p> <p><u>Station No. 1 Node</u></p> <ul style="list-style-type: none"> • Shift the distribution of the Total Minimum Bypass Flow below Station No. 1 (Article A120) to increase the Total Minimum Flow below Turners Falls Dam (Article A110) from April 1 to June 30 until 90% of the adult American Shad run enter the Spillway Lift, upon which it will revert back to the flow requirements in Articles A110 and A120. The Total Minimum Bypass Flow below Station No. 1 remains the same from April 1 to June 30 as described in Article A120. <p><u>Spillway Lift</u></p> <ul style="list-style-type: none"> • Adjust the new plunge pool release and/or bascule gate operation and/or, • Adjust the new fish lift attraction water and entrance conditions and/or, • Adjust the timing and frequency of lift operations and/or; • Adjust the entrance gate. 	<p>Years of Initial Effectiveness Testing: Years 10-11</p> <p>Time Needed to Implement AMM(s): Year 0 since all Tier 1 AMMs are operational</p> <p>Years of Post AMM Effectiveness Testing: Years 13-14</p>

Effectiveness Testing of Juvenile American Eel- Year 14

The Licensee shall conduct effectiveness testing in Year 14 to evaluate the internal efficiency of the permanent eelway structure(s) and compare the findings to the performance goals in Article 310.

- At the election of the Licensee, the Licensee may provide the effectiveness study report to an Independent Peer Review Panel (IPRP) of experts to evaluate the study results. The IPRP will consist of one member selected by the Licensee, one member selected collectively by MDFW, NMFS, and USFWS, and one member selected jointly by the Licensee, MDFW, NMFS, and USFWS. After the IPRP's review of the effectiveness study findings, the IPRP will evaluate the ability to achieve the upstream fish passage performance goals in Article 310 and provide a summary report of its findings to the Licensee, MDFW, NMFS, and USFWS within 3 months of receiving the effectiveness study report.
- If the 75% passage efficiency/48-hour time-to-pass performance goal is not met, the Licensee shall consult MDFW, NMFS, and USFWS to determine whether the 75% passage efficiency goal is achievable or should be reduced, and/or the 48-hour time-to-pass goal is achievable or should be increased. Any modifications to the 75% passage efficiency/48-hour time-to-pass must be agreed to by the Licensee, MDFW, NMFS, and USFWS.
- The Licensee shall consult MDFW, NMFS, and USFWS to determine what, if any, AMMs will be implemented.
- The Licensee shall file the effectiveness study report and documentation of any AMMs with the Commission.

If warranted, the Licensee shall consult MDFW, NMFS and USFWS on when to implement either the remaining Tier 1 AMMs and/or Tier 2 AMMs.

Tier 1 and/or Tier 2 Adaptive Management Measures Effectiveness Testing of Adult American Shad- Years 18 and 19

The Licensee shall conduct any Tier 1 and/or Tier 2 AMM effectiveness testing in Years 18 and 19 and conduct the following:

- The Licensee shall compare the effectiveness study results to the performance goals in Article 310.
- The Licensee shall provide the effectiveness study report to MDFW, NMFS and USFWS by February 1 of Years 19 and 20.
- The Licensee shall file the effectiveness study report and documentation of any AMMs with the Commission.

If, after the Licensee implements additional Tier 1 AMMs and/or Tier 2 AMMs, the overall passage efficiency is greater than 65% or a lesser number as agreed to by the Licensee, MDFW, NMFS, and USFWS, and the overall time-to-pass is less than 60 hours or a higher number as agreed by the same group, then MDFW, NMFS, and USFWS will not exercise any reserved or other regulatory authority to require additional upstream fish passage measures or operational changes.

MDFW, NMFS, and USFWS have agreed, consistent with the terms of the Flows and Fish Passage Settlement Agreement (March 2023), not to exercise any reserved or other regulatory authority regarding upstream passage to request or require any AMMs other than those listed in the table below for the first 25 years of the license. In addition, MDFW, NMFS, and USFWS have agreed, consistent with the terms of the settlement agreement, that they will not request or require Cabot Station shutdowns or a lift at Cabot Station over the life of the license.

Adaptive Management Measure (if needed)	Timing
<ul style="list-style-type: none"> • Modify the downstream passage conveyance design to increase water depth; • Modify the area of flow convergences of the trash trough, Uniform Acceleration Weir, eel pipe, and sluiceway; • Modify the area of flow convergence of the sluiceway and the receiving waters in the Connecticut River (e.g., adjustable lip, velocity control, and plunge pool depth) 	<p>Testing at Turners Falls Dam Plunge Pool (if needed): Years 14-15</p> <p>Round 3 AMM Effectiveness Testing at Cabot Station and/or Station No. 1 (if needed) and Round 2 Effectiveness Testing at Turners Falls Dam Plunge Pool (if needed): Years 18-19</p>

Article A330. Upstream Fish Passage Initial Effectiveness Studies, Adaptive Management Measures and Subsequent Effectiveness Testing

Initial Effectiveness Testing of Adult American Shad- Years 10 and 11

The Licensee shall conduct initial effectiveness testing in Years 10 and 11 (see Article 310) to evaluate upstream fish passage efficiency and time-to-pass at the Cabot Station tailrace, Rawson Island, Station No. 1 tailrace, and at the Spillway Lift through the Gatehouse Ladder exit and compare the findings to the performance goals in Article 310. The Licensee shall develop a report by February 1 of Years 11 and 12 for adult American Shad summarizing the effectiveness study findings and provide it to MDFW, NMFS, and USFWS. The Licensee shall consult MDFW, NMFS, and USFWS on the effectiveness study results and determine what, if any, Tier 1 adaptive management measures (AMMs) from the table below may be implemented.

The Licensee's implementation of Tier 1 AMMs, if warranted, will be informed by the initial effectiveness testing results. While the overall passage efficiency goal is 75% in 48 hours, there are four locations (or nodes) of interest, where the Licensee can provide enhancements as part of the AMMs for upstream passage efficiency including Cabot Station, Rawson Island, Station No. 1 and the Spillway Lift. If the individual passage efficiency at all four locations is 90% or higher, or if the overall passage efficiency goals are met, no Tier 1 AMMs will be implemented. If the individual passage efficiency at any of the four locations is less than 90%, the Licensee shall target Tier 1 enhancements to achieve an individual location passage efficiency of 90% or higher. However, if the Licensee, MDFW, NFMS, and USFWS agree that improvements can be made at other nodes that would improve the overall passage efficiency a comparable amount as an enhancement to achieve an individual location/node to at least 90%, then that enhancement can be implemented.

If warranted, the Licensee shall consult MDFW, NMFS and USFWS on when to implement the Tier 1 AMMs.

Tier 1 Adaptive Management Measures Effectiveness Testing of Adult American Shad- Years 13 and 14

The Licensee shall conduct Tier 1 AMM effectiveness testing in Years 13 and 14 and conduct the following:

- The Licensee shall compare the effectiveness study results to the performance goals in Article 310.
- The Licensee shall provide the effectiveness study report to MDFW, NMFS and USFWS by February 1 of Years 14 and 15.

- File the effectiveness study report and documentation of any AMMs with the Commission.

If warranted, the Licensee shall consult MDFW, NMFS and USFWS on when to implement any Round 2 AMMs at Station No. 1 and/or Cabot Station and Round 1 AMMs at the Turners Falls Dam plunge pool.

Effectiveness Testing of Round 2 AMMs at Station No. 1 and/or Cabot Station and Round 1 AMMs at Turners Falls Dam Plunge Pool- Years 14 and 15

The Licensee shall conduct Round 2 AMM effectiveness testing at Station No. 1 and/or Cabot Station and Round 1 AMMs at the Turners Falls Dam plunge pool in Years 14 and 15. The Licensee shall follow the same consultations steps bulleted above; however, the Licensee shall provide the effectiveness study report to MDFW, NMFS, and USFWS by February 1 of Years 15 and 16 for adult American Shad and by April 1 of Years 15 and 16 for juvenile American Shad and adult American Eel.

If warranted, the Licensee shall consult MDFW, NMFS and USFWS on when to implement any Round 3 AMMs at Station No. 1 and/or Cabot Station and Round 2 AMMs at the Turners Falls Dam plunge pool.

Effectiveness Testing of Round 3 AMMs at Station No. 1 and/or Cabot Station and Round 2 AMMs at Turners Falls Dam Plunge Pool- Years 18 and 19

The Licensee shall conduct Round 3 AMM effectiveness testing at Station No. 1 and/or Cabot Station and Round 2 AMMs at the Turners Falls Dam plunge pool in Years 18 and 19. The Licensee shall follow the same consultations steps bulleted above however, the Licensee shall provide the effectiveness study report to MDFW, NMFS, and USFWS by February 1 of Years 19 and 20 for adult American Shad and by April 1 of Years 19 and 20 for juvenile American Shad and adult American Eel.

MDFW, NMFS, and USFWS have agreed, consistent with the terms of the Flows and Fish Passage Settlement Agreement (March 2023), not to exercise any reserved or other regulatory authority regarding downstream passage to request or require any AMMs other than those listed in the table below for the first 25 years of the license. In addition, MDFW, NMFS, and USFWS have agreed, consistent with the terms of the settlement agreement, that they will not request or require Cabot Station shutdowns over the life of the license.

Downstream Adaptive Management Measures

Adaptive Management Measure (if needed)	Timing
<u>Turners Falls Dam</u> <ul style="list-style-type: none"> • Modify the bascule gate setting(s) and resultant spill (rate, location). 	Initial Effectiveness Testing at Cabot Station and Station No. 1: Years 6-7.
<u>Station No. 1</u> <ul style="list-style-type: none"> • Install a behavioral barrier. 	Initial Effectiveness Testing at Turners Falls Dam Plunge Pool and Round 1 Effectiveness Testing for any AMMs implemented at Cabot Station and/or Station No. 1 (if needed): Years 10-11.
<u>Cabot Station</u> <ul style="list-style-type: none"> • Modify the downstream passage conveyance design to reduce impact velocities and shear stresses (e.g., pump-back system; gradient reduction; piping, lining); 	Round 2 AMM Effectiveness Testing at Cabot Station and/or Station No. 1 (if needed) and Round 1 Effectiveness

Upstream Passage

- 75% of adult American Shad arriving 500 meters below Cabot Station successfully pass into the Turners Falls Impoundment within 48 hours. The 75% passage efficiency for American Shad will be based on the first 90% of the American Shad run. The effectiveness testing will be conducted over the entire adult American shad run, but the 75% passage efficiency goal will be based on the first 90% of the run as determined by the Licensee as *a posteriori* analysis of run counts. The Licensee will determine where and how run counts will occur in consultation with MDFW, NMFS and USFWS during effectiveness study plan development. The Licensee, MDFW, NMFS and USFWS will revisit whether the 75% passage efficiency goal is achievable or should be reduced, and whether the 48-hour time-to-pass goal is achievable or should be increased, after implementing the first (Tier 1) and second (Tier 2) round of AMMs as described in Article A330.
- An internal passage efficiency of 95% within the permanent passage structure(s) for American Eel. The 95% internal efficiency assumes it is possible for the Licensee to successfully tag up-migrating eels. The Licensee shall consult MDFW, NMFS, and USFWS on the appropriate size American eel, based on available technology, to test the internal efficiency.

Article A320. Downstream Fish Passage- Initial Effectiveness Studies, Adaptive Management Measures and Subsequent Effectiveness Studies

Initial Effectiveness Studies- Years 6 and 7

The Licensee shall conduct initial effectiveness testing in Years 6 and 7 (see Article 310) to evaluate the fish passage survival and time-to-pass of the newly constructed Station No. 1 bar rack and Cabot Rack and Conveyance Structure and compare the findings at individual components (e.g., Cabot Station and Station No. 1) to the performance goals in Article 310. The Licensee shall develop reports by February 1 of Years 7 and 8 for adult American Shad and by April 1 of Years 7 and 8 for juvenile American Shad and adult American Eel summarizing the survival study findings and provide it to MDFW, NMFS, and USFWS. The Licensee shall consult MDFW, NMFS, and USFWS on the effectiveness study results and determine what, if any, adaptive management measures (AMMs) may be implemented from the table below. The Licensee will target any AMMs to those locations where fish passage performance goals are not achieved. The Licensee shall file a report with the Commission to include the effectiveness testing report and documentation of any AMMs agreed to by the Licensee, MDFW, NMFS, and USFWS, along with any consultation records. If warranted, the Licensee shall consult MDFW, NMFS, and USFWS on when to implement the Round 1 AMMs at Station No. 1 and/or Cabot Station.

Effectiveness Testing of Round 1 AMMs at Station No. 1 and/or Cabot Station and Initial Effectiveness Testing at Turners Falls Dam Plunge Pool- Years 10 and 11

The Licensee shall conduct Round 1 AMM effectiveness testing at Station No. 1 and/or Cabot Station and initial effectiveness testing of the Turners Falls Dam plunge pool in Years 10 and 11. The Licensee shall:

- Compare the effectiveness study results to the performance goals in Article 310.
- Provide the effectiveness study report to MDFW, NMFS, and USFWS by February 1 of Years 11 and 12 for adult American Shad and by April 1 of Years 11 and 12 for juvenile American Shad and adult American Eel summarizing the survival study findings.
- Consult MDFW, NMFS, and USFWS to determine what, if any AMMs may be implemented from the table below and target AMMs to those locations where passage performance goals are not achieved.

Facility	Operational/Shakedown Date	Initial Effectiveness Study Years and Locations to be Tested
Rehabilitate Gatehouse Trapping Facility (Sampling Facility)	Year 9 (by April 1 st) after license issuance	Not Applicable
Retire Cabot Ladder and Portions of Gatehouse Ladder	No later than Year 11 after license issuance (tied to within 2 years after the Spillway Lift becomes operational).	Not Applicable
Permanent Eel Passage Structure(s)	Year 13 after license issuance	Year 14, the internal efficiency of the permanent eel passage structure(s) will be tested.

¹Relative to the Cabot Intake Protection and Downstream Passage Conveyance and the Station No. 1 Bar Rack, the times cited are from license issuance based on the time needed to complete construction. The actual first year of operation of these two facilities will depend on when the license is issued. If the license is issued in quarter 1 (Q1, Jan 1-Mar 31) then these two facilities will be operational no later than April 1 of Year 4 after license issuance; if it is issued in Q2 then these two facilities will be operational no later than August 1 of Year 4 after license issuance; and if it is issued after Q2 then these two facilities will be operational no later than April 1 of Year 5 after license issuance.

Consultation Process on Effectiveness Study Plans

For any initial fish passage effectiveness studies and any subsequent fish passage effectiveness studies required after implementing any AMMs described in Article A320 and A330, the Licensee shall provide the effectiveness study plans to MDFW, NMFS, and USFWS and request comments on the study plans within 30 days. The Licensee shall consult MDFW, NMFS, and USFWS and obtain their approval on the study plans before conducting the effectiveness studies. The Licensee shall file the effectiveness study plans with the Commission, along with any consultation records.

Fish Passage Performance Goals

The Licensee shall compare the effectiveness study results to the following fish passage performance goals:

Downstream Passage

- 95% of juvenile American Shad arriving 500 meters upstream of the Turners Falls Dam survive migration past the Turners Falls Project within 24 hours.
- 95% of adult American Shad arriving 1 kilometer upstream of the Turners Falls Dam survive migration past the Turners Falls Project within 24 hours.
- 95% of American Eel arriving 1 kilometer upstream of the Turners Falls Dam survive migration past the Turners Falls Project within 48 hours of a flow event. The definition of what constitutes a flow event shall be determined by the Licensee in consultation with MDFW, NMFS and USFWS during effectiveness study plan development.

The downstream passage at the Turners Falls Project is project wide and will include all routes of passage (e.g., spill, fish bypass, and turbine passage).

¹Relative to the Cabot Intake Protection and Downstream Passage Conveyance and the Station No. 1 Bar Rack, the times cited are from license issuance based on the time needed to complete construction. The actual first year of operation of these two facilities will depend on when the license is issued. If the License is issued in quarter 1 (Q1, Jan 1-Mar 31) then these two facilities will be operational no later than April 1 of Year 4 after license issuance; if it is issued in Q2 then these two facilities will be operational no later than August 1 of Year 4 after license issuance; and if it is issued after Q2 then these two facilities will be operational no later than April 1 of Year 5 after license issuance.

- (h) Construct a plunge pool downstream of the Turners Falls Dam Bascule Gate No. 1 as part of the construction of the Spillway Lift, to be operational no later than April 1 of Year 9 after license issuance.

Consultation

For any new fish passage facility, the Licensee shall consult and obtain approval from MDFW, NMFS, and USFWS on the facility design and on operation and maintenance procedures. The Licensee shall consult MDFW, NMFS, and USFWS at the 30%, 60%, 90% and 100% design plan milestones. The Licensee shall file the 100% design plans with the Commission, along with documentation of consultation with MDFW, NMFS, and USFWS. If any fish passage adaptive management measures (AMMs) are implemented as discussed in Articles A320 and A330 and require facility design and operation and maintenance procedures, then the Licensee shall follow the same consultation process as the initial fish passage build-out.

The Commission reserves the right to require changes to the design plans. Implementation of the design plans will not begin until the Licensee is notified by the Commission that the design plans are approved. Upon Commission approval, the Licensee shall implement the design plans, including any changes required by the Commission.

Article A310. Schedule of Initial Effectiveness Testing, Consultation Process on Effectiveness Testing Study Plans, and Fish Passage Performance Goals

Schedule of Initial Effectiveness Testing

The Licensee shall complete construction of each fish passage facility, operate the fish passage facility for one season (shakedown year), and then conduct representative and quantitative fish passage effectiveness testing per the schedule below.

Facility	Operational/Shakedown Date	Initial Effectiveness Study Years and Locations to be Tested
Cabot Rack and Downstream Conveyance	Year 4 after license issuance ¹	Years 6-7, the Cabot Downstream Fish Passage Structure and Station No. 1 Rack will be tested.
Station No. 1 Bar Rack	Year 4 after license issuance ¹	
Turners Falls Dam Plunge Pool	Year 9 (by April 1 st) after license issuance	Years 10-11, the Turners Falls Plunge Pool and Spillway Lift will be tested.
Spillway Lift	Year 9 (by April 1 st) after license issuance	

- (b) rehabilitate the Gatehouse Trapping facility (sampling facility) to be operational no later than April 1 of Year 9 after license issuance.
- (c) retire, either by removal or retaining in place, the Cabot Ladder and the power canal portions of the Gatehouse Ladder within 2 years after the Spillway Lift becomes operational.
- (d) install and operate interim upstream eel passage in the vicinity of the existing Spillway Ladder within 1 year of license issuance and continue operating it until permanent upstream eel passage facilities are operational. The Licensee shall consult MDFW, NMFS, and USFWS on the location and design of the interim eelway(s).
- (e) conduct up to 2 years of eelway siting studies after the Spillway Lift becomes operational, using a similar methodology to relicensing Study 3.3.4 for both years. Based on the siting survey results, design, construct, operate, and maintain up to two permanent upstream eel passage facilities at the Turners Falls Project no later than 3 years after completing the final siting survey. The Licensee shall consult MDFW, NMFS, and USFWS on the location of the two permanent upstream eel passage facilities. The final eelway siting will take into account the ability to maintain the eelway(s) in light of spillage conditions at the Turners Falls Project. The Licensee will not be required to place any eelways at the foot of any active spillway structures.

Downstream Fish Passage

- (f) Within 4 years¹ of license issuance, replace the existing Cabot Station trashrack structure with a new full depth trashrack with 1-inch clear spacing. The new trashracks will have multiple openings for fish passage, including openings on the top and bottom of the water column. The Licensee will attempt to maximize the hydraulic capacity of these openings within the constraints of the conveyance mechanisms. The Licensee will base detailed design alternatives on the following conceptual design; however, the Parties will remain flexible on design alternatives as necessary to meet fish passage goals.

The new trashrack will have multiple surface entrances including a.) between Cabot Units 2 and 3; b.) between Cabot Units 4 and 5; and c.) at the right wall of the intake (looking downstream) at Cabot Unit 6. The openings will be 3-feet-wide by 2-feet-tall and will connect to the existing trash trough located behind the racks. Each opening at the top of the trashrack will have an approximate hydraulic capacity of 24 cfs, and the existing trash trough will convey a total hydraulic capacity of approximately 72 cfs from these openings. The new trashrack will have an additional entrance near the bottom at the left wall of the intake (looking downstream) at Unit 1. This entrance will be approximately 3-feet-wide by 3-feet-tall and will connect to a vertical pipe to safely convey fish to the existing trash trough or log sluice. This entrance will be sized to provide a velocity that attracts fish to the bypass relative to the turbine intakes (approximately 5 feet-per-second). In addition to the entrances integral to the new trashrack structure, fish will be conveyed via a new uniform acceleration weir (UAW) and log sluice. The log sluice will be resurfaced to limit turbulence and injury to migrants. A steel panel (or equivalent) will be provided below the UAW to exclude migrants from being delayed in the space below the UAW. Total flow from all downstream passage components at Cabot Station will be 5% (685 cfs) of maximum hydraulic station capacity (13,728 cfs). The conveyance at each bypass entrance will be determined during the design phase.

- (g) Within 4 years¹ of license issuance, construct a ¾-inch clear-spaced bar rack at the entrance to the Station No. 1 branch canal.

- **Categorize Allowable Deviations:** When an allowable deviation is identified it will be categorized as either Regulatory, as detailed in paragraph (b) of Article A160, NRF Allowance, as detailed in paragraph (d) of the Article A190 or Discretionary, as detailed in paragraph (a) of Article A160.

The Licensee shall develop the Plan after consultation with MDEP, MDFW, NMFS, and USFWS. The Licensee shall include with the Plan documentation of consultation after it has been prepared and provided to MDEP, MDFW, NMFS, and USFWS. The Licensee shall provide a minimum of 30 days for MDEP, MDFW, NMFS, and USFWS to comment and to make recommendations before filing the Plan with the Commission. If the Licensee does not adopt a recommendation, the filing will include the Licensee's reasons, based on project-specific information.

The Commission reserves the right to require changes to the Plan. Implementation of the Plan will not begin until the Licensee is notified by the Commission that the Plan is approved. Upon Commission approval, the Licensee shall implement the Plan, including any changes required by the Commission.

Article A210. Flow Notification and Website

Within 1 year of license issuance, the Licensee shall provide the following information year-round on a publicly available website:

- (a) On an hourly basis, the Turners Falls Impoundment water elevation, as measured at the Turners Falls Dam, the Turners Falls Dam total discharge, and the Station No. 1 discharge.
- (b) On an hourly basis, the anticipated Turners Falls Dam total discharge and the anticipated Station No. 1 discharge for a 12-hour window into the future. Should the Licensee deviate from passing the 12-hour previous NRF from December 1 to May 31 or the 12-hour average NRF from June 1 to November 30, it will post the revised flows (in the 12-hour look ahead window) to a website as soon as practicable after they are known. Should the Licensee of the Vernon Hydroelectric Project provide the Licensee with flow data more than 12 hours in advance, the Licensee shall publish the information sooner.
- (c) Within one month prior to its annual power canal drawdown, the Licensee shall post on its website the starting and ending time/date of the drawdown, which will last at least 4 days. Throughout the duration of the canal drawdown, the NRF, as defined in Article A110, will be maintained below the Turners Falls Dam.

Article A300. Fish Passage Facilities and Consultation

The Licensee shall implement the following fish passage measures on the schedule specified. When due dates cited in this and other articles are in "years after license issuance," this shall mean on the appropriate date in the specified calendar year after license issuance, regardless of the quarter in which the license is issued. For example, "Year 1 after license issuance" begins on the first January 1 following license issuance.

Upstream Fish Passage

- (a) construct a Spillway Lift at the Turners Falls Dam to be operational no later than April 1 of Year 9 after license issuance.

±10% of NRF resulting from conflicting operational requirements will not count against any time allotment for allowable deviations outlined in this paragraph.

Article A200. Project Operation, Monitoring and Reporting Plan

Within 1 year of license issuance, the Licensee shall file with the Commission, for approval, a Project Operation, Monitoring and Reporting Plan describing how the Licensee will document compliance with the operating conditions. The Plan will include the following:

- (a) a description of how the Licensee will comply with Minimum Flows below Turners Falls Dam (Article A110), Total Minimum Bypass Flows below Station No. 1 (Article A120), Minimum Flows below Cabot Station (Article A130), Cabot Station Ramping Rates (Article A140), Variable Releases from Turners Falls Dam and Variable Flow below Station No. 1 (Article A150), Flow Stabilization below Cabot Station (Article A160, implementation starting 3 years after license issuance), and Turners Falls Impoundment Water Level Management (Article A190). These are collectively referred to hereinafter as the operating requirements.
- (b) a provision to file with the Commission, after consultation with the MDEP, MDFW, NFMS, and USFWS, a minimum flow and operation compliance report detailing implementation of the plan, including any allowable deviations that occurred during the reporting period. For the period January 1 to March 31 and July 1 to December 31, the compliance report, including any deviations, will be filed with the Commission by March 1 of the following year. For the months of April, May and June, the monthly compliance report, including any deviations, will be filed with the Commission on June 1, July 1 and August 1, respectively. Upon license issuance until 3 years thereafter, the Licensee shall document on an hourly basis for each day any allowable deviations from the Cabot Station Ramping Rates (Article A140) and demonstrate progress towards meeting the Flow Stabilization below Cabot Station (Article A160). Beginning three years after license issuance until license expiration, the Licensee shall document on an hourly basis for each day any allowable deviations from the Cabot Station Ramping Rates restrictions (Article A140) and Flow Stabilization below Cabot Station restrictions (Article A160). Each day, from April 1 to November 30, the Licensee shall record any allowable deviations in a spreadsheet showing the daily deviations, the reason for the deviation, the number of hours, and scope. The Licensee shall provide the total number of deviations to the MDEP, MDFW, NFMS, and USFWS per the reporting schedule above. Allowable deviations will be tracked as follows:
 - Identify Allowable Deviations: The Licensee shall record the NRF, Turners Falls Dam discharge, Station No. 1 discharge, Cabot Station discharge and total Turners Falls Project discharge (below the Cabot Station tailrace) at the top of each hour. Allowable deviations in both the Cabot Station Ramping Rate and Flow Stabilization below Cabot Station requirements will be recorded. At the top of each hour, the Licensee shall record the change in Cabot Station discharge from the previous hour to determine if any deviation has occurred from the agreed upon Cabot Station Ramping Rate. In addition, the NRF (as detailed in paragraph (b) of the "Operational Regime" section) will be compared with the recorded total Turners Falls Project discharge in a given hour to identify if a Flow Stabilization below Cabot Station deviation occurred over the past hour. Any deviation of either the Cabot Station Ramping Rate or total Turners Falls Project discharge within the hour will be counted in one-hour increments.

Article A170. Flood Flow Operations

Upon license issuance, the Licensee shall operate the Project in accordance with its existing agreement with the United States Army Corps of Engineers (USACE). This agreement, memorialized in the Reservoir and River Flow Management Procedures (1976), as it may be amended from time to time, governs how the Turners Falls Project will operate during flood conditions and coordinate its operations with the Licensee of the Northfield Mountain Pumped Storage Project (FERC No. 2485).

Article A180. Cabot Station Emergency Gate Use

Upon license issuance, the Licensee will use the Cabot Station Emergency Gates under the following conditions: a) a Cabot load rejection which could cause overtopping of the canal, b) dam safety issues such as potential canal overtopping or partial breach, and c) to discharge up to approximately 500 cfs from April 1 to June 15 for debris management. The Licensee shall avoid discharging flows higher than 500 cfs through the gates from April 1 to June 15 if practicable; however, if necessary to discharge higher flows, the Licensee shall coordinate with NMFS to minimize potential impacts to Shortnose Sturgeon in the area below Cabot Station.

Article A190. Turners Falls Impoundment Water Level Management

Upon license issuance, the Licensee shall operate the Turners Falls Impoundment, as measured at the Turners Falls Dam, as follows:

- (a) Maintain water levels between elevation 176.0 feet and 185.0 feet National Geodetic Vertical Datum of 1929 (NGVD29).
- (b) Limit the rate of rise of the Turners Falls Impoundment water level to be less than 0.9 feet/hour from May 15 to August 15 from 8:00 am to 2:00 pm. However, if the NRF is greater than the sum of the hydraulic capacity of Cabot Station and Station No. 1 and the Minimum Flow below Turners Falls Dam in effect at the time, the Turners Falls Impoundment rate of rise requirement will not apply.
- (c) The rate of rise of the Turners Falls Impoundment may be temporarily modified if required by equipment malfunction or operating emergencies reasonably beyond the control of the Licensee. If the rate of rise of the Turners Falls Impoundment is so modified, the Licensee shall notify the Commission, MDEP, MDFW, NMFS, and USFWS as soon as possible, but no later than 10 days after such incident. The rate of rise of the Turners Falls Impoundment may also be temporarily modified for short periods upon mutual agreement with the Licensee for the Northfield Mountain Pumped Storage Project (FERC No. 2485), MDEP, MDFW, NMFS, and USFWS, and upon 5 days' notice to the Commission.
- (d) The Licensee may increase the allowable NRF deviation from $\pm 10\%$ to $\pm 20\%$ to better manage Turners Falls Impoundment water levels. The increased flow deviation is limited by the number of hours shown in the first table of Article A160. This allowance for an increased flow deviation is in addition to the exceptions outlined in paragraphs (a) and (b) of Article A160. As such, the increased flow allowable deviations outlined in this paragraph will not count against any time allotment for exceptions outlined in paragraphs (a) and (b) of Article A160. Similarly, operations meeting the exception criteria outlined in paragraphs (a) and (b) of Article A160 will not count against any time allotment for allowable deviations outlined in this paragraph. Allowable flow deviations in excess of

transmission and power system requirements, and other regulatory requirements as defined in paragraph (b) below.

- (a) The Licensee may deviate from the Flow Stabilization below Cabot Station and Cabot Station Ramping Rates (Article A140). The number of hours of flexible operations, which may be used at the discretion of the Licensee, are as follows.

Date	Allowable Deviations from Cabot Station Ramping Rates (Article A140) and Flow Stabilization below Cabot Station
07/01-07/31	20 hours of flexible operations with no more than 7 flexible events per month
08/01-08/31	26 hours of flexible operations with no more than 7 flexible events per month
09/01-09/30	23 hours of flexible operations with no more than 7 flexible events per month
10/01-10/31	20 hours of flexible operations with no more than 7 flexible events per month
11/01-11/30	28 hours of flexible operations with no more than 7 flexible events per month

- (b) If compliance with the Flow Stabilization below Cabot and Cabot Station Ramping Rates (Article A140) would cause the Licensee to violate or breach any law, any applicable license, permit, approval, consent, exemption or authorization from a federal, state, or local governmental authority, any applicable agreement with a governmental entity, the Licensee may deviate from the Flow Stabilization below Cabot and Cabot Station Ramping Rates (Article A140) to the least degree necessary to avoid such violation or breach. The Licensee may also deviate from the Flow Stabilization below Cabot and Cabot Station Ramping Rates for the following reasons:

- (1) To implement Flood Flow Operations as defined in Article A170.
- (2) To perform demonstrations of the resources' operating capabilities under ISO-NE, or its successors, rules and procedures such as, maintaining the Licensee's capacity accreditation (or its successor) or its fast start reserve eligibility. The Licensee shall seek to perform these demonstrations at times that will not cause it to deviate from the conditions in Articles A110-A160, with recognition that April 1 to June 30 should be avoided, to the maximum extent possible.
- (3) To manage the Turners Falls Impoundment to stay within its licensed operating limits in Article A190, with recognition that deviations from April 1 to June 30 should be avoided to the maximum extent possible.
- (4) If compliance with Articles A110-A160 would cause a public safety hazard or prevent timely rescue.

*ISO-NE, or its successors, (or another recognized entity with responsibilities for regional energy and capacity supply) requirements are circumstances when ISO-NE requires the Licensee to be fully available and, if necessary, responsive.

The Flow Stabilization below Cabot Station may be temporarily modified if required by equipment malfunction or operating emergencies reasonably beyond the control of the Licensee. If the Flow Stabilization below Cabot Station is so modified, the Licensee shall notify the Commission, MDEP, MDFW, NMFS, and USFWS as soon as possible, but no later than 10 days after such incident. The Flow Stabilization below Cabot Station may also be temporarily modified for short periods upon mutual agreement with the Licensee for the Northfield Mountain Pumped Storage Project (FERC No. 2485), MDEP, MDFW, NMFS, and USFWS, and upon 5 days' notice to the Commission.

FLOW, and USFWS as soon as possible. The Turners Falls Dam variable release or variable flow below Station No. 1 may also be temporarily modified for short periods upon mutual agreement with the Licensee for the Northfield Mountain Pumped Storage Project (FERC No. 2485), AW, AMC, commercial outfitters, MDEP, MDFW, NMFS, NPS, NE FLOW and USFWS.

Article A160. Flow Stabilization below Cabot Station and Allowable Deviations for Flexible Operations

Three years after license issuance, the Licensee shall maintain $\pm 10\%$ of the NRF below Cabot Station as follows.

Date	Flow Stabilization below Cabot Station ¹
04/01-05/15 ²	Provide $\pm 10\%$ of the NRF below Cabot Station from 7:00 pm to midnight, with allowable deviations up to $\pm 20\%$ of the NRF for up to 22 hours total from 04/01-05/15 (the 22 hours will be used from 7:00 pm to midnight).
05/16-05/31 ²	Provide $\pm 10\%$ of the NRF below Cabot Station from 7:00 pm to midnight, with allowable deviations up to $\pm 20\%$ of the NRF for up to 18 hours total from 05/16-05/31 (the 18 hours will be used from 7:00 pm to midnight).
06/01-06/15 ²	Provide $\pm 10\%$ of the NRF below Cabot Station with allowable deviations up to $\pm 20\%$ of the NRF for up to 7 hours total from 06/01-06/15.
06/16-06/30 ²	Provide $\pm 10\%$ of the NRF below Cabot Station with allowable deviations up to $\pm 20\%$ of the NRF for up to 7 hours total from 06/16-06/30.
07/01-08/15 ³	Provide $\pm 10\%$ of the NRF below Cabot Station with allowable deviations up to $\pm 20\%$ of the NRF for up to 55 hours total from 07/01-08/15.
08/16-08/31 ³	Provide $\pm 10\%$ of the NRF below Cabot Station with allowable deviations up to $\pm 20\%$ of the NRF for up to 27 hours total from 08/16-08/31.
09/01-10/31 ³	Provide $\pm 10\%$ of the NRF below Cabot Station with allowable deviations up to $\pm 20\%$ of the NRF for up to 44 hours total from 09/01-10/31.
11/01-11/30 ³	Provide $\pm 10\%$ of the NRF below Cabot Station with allowable deviations up to $\pm 20\%$ of the NRF for up to 11 hours total from 11/01-11/30.

¹If the NRF is greater than the sum of the hydraulic capacity of Cabot Station and Station No. 1 and the Minimum Flow below Turners Falls Dam in effect at the time, the Flow Stabilization below Cabot Station will not apply.

²From April 1 to June 30, the NRF flow may be reduced by 10% or up to 20% for select hours. If the NRF is reduced during this period, the flow will be taken from Cabot Station generation.

³From July 1 to November 30, the NRF flow may be reduced by 10% or up to 20% for select hours. If the NRF is reduced during this period, the flow will not be taken from the Turners Falls Dam Minimum Flow.

Beginning three years after license issuance, the Licensee may deviate from the Flow Stabilization below Cabot Station and Cabot Station Ramping Rates (Article A140) for a certain number of hours in July, August, September, October and November, hereinafter referred to as flexible operations.

The Licensee has restricted discretionary flexible operating capability to respond to elevated energy prices, as defined in paragraph (a) below, from July 1 to November 30, as well as unrestricted capability to respond to emergencies, Independent System Operator-New England (ISO-NE, or its successors)

At the beginning of the variable release, if the NRF is between 2,500 and 4,000 cfs, the Licensee shall up ramp at 50% of the NRF per hour.

⁶At the end of the variable release, if Turners Falls Dam variable release is between 2,500 and 4,000 cfs, the Licensee shall down ramp at 50% of the variable release per hour.

Variable Flow below Station No. 1

Magnitude of Variable Flow below Station No. 1	¹ 2,500 cfs, or the NRF, whichever is less
Dates when Variable Flow may occur	² July 1 through October 31
Total No. of 2-day events	7 events for a total of 14 Variable Flows
Days of Variable Flow	Saturday and Sunday- must be two consecutive days
Hours of Variable Flow	10:00 am to 2:00 pm, 4 hrs/day
Magnitude of Variable Flow below Station No. 1 from Saturday at 2:00 pm to Sunday at 10:00 am.	See Footnote 3

¹If the NRF < 2,500 cfs, during the scheduled flow (see footnote 2 below relative to scheduling the flow), there will be no 2,500 cfs flow and it will not be rescheduled.

²The Licensee shall consult AW, AMC, commercial outfitters, MDEP, MDFW, NPS, NE FLOW, and USFWS no later than March 1 annually over the license term to develop a mutually agreeable schedule for the variable flow. When developing the schedule there will be at least one weekend per month, between July 1 and October 31, when no variable flow is provided.

³From July 1 to August 31, the Total Minimum Bypass Flow below Station No. 1 is defined in Article A120. If the NRF is > 1,800 cfs, the Total Minimum Bypass below Station No. 1 shall be 1,800 cfs, or 90% of the NRF, whichever is less. The magnitude of flow below Station No. 1 from Saturday at 2:00 pm to Sunday at 10:00 am from July 1 to August 31 will be computed as follows:

$(2,500 \text{ cfs} + \text{Total Minimum Flow below Station No. 1 as defined in Article A120})/2.$

From September 1 to November 15, the Total Minimum Bypass Flow below Station No. 1 is defined in Article A120. If the NRF is > 1,500 cfs, the Total Minimum Bypass below Station No. 1 shall be 1,500 cfs, or 90% of the NRF, whichever is less. The magnitude of flow below Station No. 1 from Saturday at 2:00 pm to Sunday at 10:00 am from September 1 to November 15 will be computed as follows:

$(2,500 \text{ cfs} + \text{Total Minimum Flow below Station No. 1 as defined in Article A120})/2.$

When implementing the variable releases from the Turners Falls Dam or the 2,500 cfs flow below Station No. 1, the Licensee is still required to maintain the operational requirements in License Articles A110, A120, A130, A140, A160 and A190.

The above variable release from the Turners Falls Dam and variable flow below Station No. 1 may be temporarily modified if required by equipment malfunction or operating emergencies reasonably beyond the control of the Licensee. If the Turners Falls Dam variable release or variable flow below Station No. 1 are so modified, the Licensee shall notify AW, AMC, commercial outfitters, MDEP, MDFW, NMFS, NPS, NE

Variable Releases from Turners Falls Dam

Magnitude of Variable Release from Turners Falls Dam	¹ 4,000 cfs, or the NRF, whichever is less
Dates when Variable Releases may occur	² July 1 through October 31
³ Total No. of 2-day events	5 events for a total of 10 Variable Releases, but could potentially be 11 Variable Releases subject to footnote 3
Days of Variable Release for 2 day-events	Saturday and Sunday- must be two consecutive days
Hours of Variable Release	10:00 am to 2:00 pm, 4 hrs/day, Saturday and Sunday
Magnitude of Variable Release from Turners Falls Dam from Saturday at 2:00 pm to Sunday at 10:00 am.	See footnote 4
⁵ Up-Ramping Rates at Start of Variable Release	See footnote 5
⁶ Down-Ramping Rates at End of Variable Release	See footnote 6

¹If the NRF < 2,500 cfs during the scheduled variable release (see footnote 2 below relative to scheduling variable releases), there will be no variable release and it will not be rescheduled.

²The Licensee shall consult American Whitewater (AW), Appalachian Mountain Club (AMC), commercial outfitters, MDEP, MDFW, National Park Service (NPS), New England FLOW (NE FLOW), and USFWS no later than March 1 annually over the license term to develop a mutually agreeable schedule for the variable releases. When developing the schedule, there will be at least one weekend per month, between July 1 and October 31, when no variable releases are provided.

³The Licensee conducts annual canal drawdowns for maintenance purposes resulting in the NRF being passed at the Turners Falls Dam. If the canal drawdown occurs between July 1 and October 31 and the NRF is being passed either on Saturday from 10:00 am- 2:00 pm or Sunday from 10:00 am-2:00 pm, the total number of releases at the Turners Falls Dam shall remain at 10 releases. However, if the canal drawdown does not occur between July 1 and October 31 on Saturday from 10:00 am-2:00 pm or Sunday from 10:00 am-2:00 pm, the Licensee shall provide an additional consecutive day of variable release such that one of the 2-day events is a 3-day consecutive event resulting in a total of 11 releases. The additional day shall either be Friday from 10:00 am-2:00 pm before the scheduled weekend variable release or Monday from 10:00 am-2:00 pm after the scheduled weekend variable release. If there ends up being one 3-day event, the magnitude of release from Friday at 2:00 pm to Saturday at 10:00 am (or Sunday at 2:00 pm to Monday at 10:00 am), shall be computed as noted in footnote 4.

⁴This flow will be calculated as: $[(\text{Variable Flow Release} - \text{Minimum Flow below Turners Falls Dam as defined in Article A110})/2]$. If there is a 3-day event as noted in footnote 3, the variable flow release from Friday at 2:00 pm to Saturday at 10:00 am (or from Sunday at 2:00 pm to Monday at 10:00 am) will be based on the same calculation.

⁵At the beginning of the variable release, if the NRF is > 4,000 cfs, the Licensee shall up-ramp from the Minimum Flow below Turners Falls Dam as defined in Article A110 to 4,000 cfs in two hours, not to exceed 2,000 cfs/hr.

¹From July 1 to November 30, the Minimum Flow below Cabot Station is 1,800 (07/01-08/31) and 1,500 cfs (09/01-11/30) or 90% of the NRF, whichever is less. If the Minimum Flow below Cabot Station is reduced by 10% during these periods, it will not be taken from the Turners Falls Dam Minimum Flow (Article A110).

The Minimum Flow below Cabot Station may be temporarily modified if required by equipment malfunction or operating emergencies reasonably beyond the control of the Licensee. If the Minimum Flow below Cabot Station is so modified, the Licensee shall notify the Commission, MDEP, MDFW, NMFS, and USFWS as soon as possible, but no later than 10 days after such incident. The Minimum Flow below Cabot Station may also be temporarily modified for short periods upon mutual agreement with the Licensee for the Northfield Mountain Pumped Storage Project (FERC No. 2485), MDEP, MDFW, NMFS and USFWS, and upon 5 days' notice to the Commission.

Article A140. Cabot Station Ramping Rates

Upon license issuance until 3 years after license issuance, the Licensee shall ramp Cabot Station as follows.

Date	Cabot Station Ramping Rates¹
04/01-06/30	Up and Down Ramping at a rate of 2,300 cfs/hour
07/01-08/15	Up Ramping at a rate of 2,300 cfs/hour from 8:00 am to 2:00 pm

Three years after license issuance, the Licensee shall ramp Cabot Station as follows.

Date	Cabot Station Ramping Rate¹
04/01-06/30	Up and Down Ramping at a rate of 2,300 cfs/hour

¹If the NRF is greater than the sum of the hydraulic capacity of Cabot Station and Station No. 1 and the Minimum Flow below Turners Falls Dam in effect at the time, the Cabot Station up-ramping rates will not apply.

The Cabot Station Ramping Rates above will take precedence over the Flow Stabilization below Cabot Station (Article A160).

The Cabot Station Ramping Rates may be temporarily modified if required by equipment malfunction or operating emergencies reasonably beyond the control of the Licensee. If the Cabot Station Ramping Rates are so modified, the Licensee shall notify the Commission, MDEP, MDFW, NMFS, and USFWS as soon as possible, but no later than 10 days after such incident. The Cabot Station Ramping Rate may also be temporarily modified for short periods upon mutual agreement with the Licensee for the Northfield Mountain Pumped Storage Project (FERC No. 2485), MDEP, MDFW, NMFS, and USFWS, and upon 5 days' notice to the Commission.

Article A150. Variable Releases from Turners Falls Dam and Variable Flow below Station No. 1

For recreation and ecological conservation purposes, upon license issuance, the Licensee shall provide variable releases from the Turners Falls Dam and a variable flow below Station No. 1 as shown below.

below Station No. 1 shall be the NRF, subject to the conditions in Article A330. If this AMM is enacted, and the NRF > 6,500 cfs, the Total Minimum Bypass Flow below Station No. 1 is 6,500 cfs, subject to the conditions in Article A330.

³From July 1 to August 31, when the NRF is greater than 1,800 cfs, the Total Minimum Bypass Flow below Station No.1 shall be 1,800 or 90% of the NRF, whichever is less. From September 1 to December 31, when the NRF is greater than 1,500 cfs, the Total Minimum Bypass Flow below Station No. 1 shall be 1,500 cfs or 90% of the NRF, whichever is less. From July 1 to December 31, if the Total Minimum Bypass Flow below Station No. 1 shall be reduced by 10%, it will not be taken from the Turners Falls Dam Minimum Flow (Article 110).

⁴The amount of flow needed from Station No. 1 from June 1 to June 30 may be modified in the future pending fish passage effectiveness studies. If the Licensee conducts fish passage effectiveness studies, in consultation with the MDFW, NMFS, and USFWS and determines that migratory fish are not delayed by passing a greater percentage of the Total Minimum Bypass Flow below Station No. 1 via Station No. 1 discharge, the Licensee may file for a license amendment to increase the magnitude of Station No. 1 discharge upon written concurrence of MDFW, NMFS, and USFWS. Prior to filing for a license amendment with the Commission, the Licensee shall consult AW, AMC, CAW, MDEP, NEF and ZO and address any comments of those entities in the license amendment filing.

If the Station No. 1 units are used to maintain the Total Minimum Bypass Flow below Station No. 1, and if some or all of the Station No. 1 units become inoperable, the balance of the flow needed to maintain the Total Bypass flow below Station No. 1 will be provided from either the Turners Falls Dam Minimum Flow (dam or canal gate), Fall River, Turners Falls Hydro, LLC or Milton Hilton, LLC.

The Total Minimum Bypass Flow below Station No. 1 may be temporarily modified if required by equipment malfunction or operating emergencies reasonably beyond the control of the Licensee. If the Total Minimum Bypass Flow below Station No. 1 is so modified, the Licensee shall notify the Commission, MDEP, MDFW, NMFS, and USFWS as soon as possible, but no later than 10 days after such incident. The total bypass flow below Station No. 1 may also be temporarily modified for short periods upon mutual agreement with the Licensee for the Northfield Mountain Pumped Storage Project (FERC No. 2485), MDEP, MDFW, NMFS, and USFWS, and upon 5 days' notice to the Commission.

Article A130. Minimum Flows below Cabot Station

Upon license issuance, the Licensee shall maintain Minimum Flows below Cabot Station, or the NRF, whichever is less, as follows.

Date	Minimum Flow below Cabot Station
01/01-03/31	3,800 cfs or the NRF, whichever is less
04/01-05/31	8,800 cfs from midnight to 7:00 pm or the NRF, whichever is less and 6,500 cfs from 7:00 pm to midnight or the NRF, whichever is less.
06/01-06/15	6,800 cfs or the NRF, whichever is less
06/16-06/30	5,800 cfs or the NRF, whichever is less
07/01-08/31 ¹	1,800 cfs or 90% of the NRF, whichever is less
09/01-11/15 ¹	1,500 cfs or 90% of the NRF, whichever is less
11/16-11/30 ¹	1,500 cfs or 90% of the NRF, whichever is less
12/01-12/31	3,800 cfs or NRF, whichever is less

*unchanged
from
previous
draft*

Date	Total Minimum Bypass Flows below Station No. 1 ¹
01/01-03/31	<ul style="list-style-type: none"> If the NRF is ≤ 400 cfs, the Total Minimum Bypass Flow below Station No. 1 shall be 400 cfs, or the NRF, whichever is less. If the NRF is > 400 cfs, the Total Minimum Bypass Flow below Station No. 1 shall be 1,500 cfs, or the NRF, whichever is less.
04/01-05/31	<ul style="list-style-type: none"> If the NRF is $\leq 6,500$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be the NRF. If the NRF is $> 6,500$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be 6,500 cfs.
06/01-06/15 ^{2,4}	<ul style="list-style-type: none"> If the NRF is $\leq 4,500$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be the NRF. If the NRF is $> 4,500$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be 4,500 cfs.
06/16-06/30 ⁴	<ul style="list-style-type: none"> If the NRF is $\leq 3,500$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be the NRF. If the NRF is $> 3,500$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be 3,500 cfs.
07/01-08/31 ³	<ul style="list-style-type: none"> If the NRF is ≤ 500 cfs, the Total Minimum Bypass Flow below Station No. 1 shall be 500 cfs, or the NRF, whichever is less. If the NRF is > 500 cfs and $\leq 1,800$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be the NRF or 90% of the NRF. If the NRF is $> 1,800$ cfs, the Total Minimum Bypass below Station No. 1 shall be 1,800 cfs, or 90% of the NRF, whichever is less.
09/01-11/15 ³	<ul style="list-style-type: none"> If the NRF is ≤ 500 cfs, the Total Minimum Bypass Flow below Station No. 1 shall be 500 cfs, or the NRF, whichever is less. If the NRF is > 500 cfs and $\leq 1,500$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be the NRF, or 90% of the NRF. If the NRF is $> 1,500$ cfs, the Total Minimum Bypass below Station No. 1 shall be 1,500 cfs, or 90% of the NRF, whichever is less.
11/16-12/31 ³	<ul style="list-style-type: none"> If the NRF is < 400 cfs, then the Total Minimum Bypass Flow below Station No. 1 shall be 400 cfs, or the NRF, whichever is less. If the NRF is > 400 cfs and $\leq 1,500$ cfs, the Total Minimum Bypass Flow below Station No. 1 shall be the NRF or 90% of the NRF. If the NRF is $> 1,500$ cfs, the Total Minimum Bypass below Station No. 1 shall be 1,500 cfs, or 90% of the NRF, whichever is less.

← Increase from 250

Agree

¹From license issuance until 3 years thereafter, Station No. 1 will not be automated. During those 3 years, if Station No. 1 is the only source, other than the Fall River, Turners Falls Hydro, LLC, or Milton Hilton, LLC to provide the additional flow needed to meet the Total Minimum Bypass Flow below Station No. 1, the Licensee shall maintain the Station No. 1 discharge such that the Turners Falls Dam Minimum Flow will be as shown in Article A110, or higher flows, in cases where the additional flow cannot be passed through Station No. 1.

²One of the upstream fish passage adaptive management measures (AMMs) described in Article A330 calls for increasing the Total Minimum Bypass Flow below Station No. 1 from June 1 to June 15 from 4,500 cfs to 6,500 cfs. If this AMM is enacted, and if the NRF is $\leq 6,500$ cfs, the Total Minimum Bypass Flow

²One of the upstream fish passage adaptive management measures (AMMs) described in Article A330 calls for increasing the Total Minimum Bypass Flow below Station No. 1 (see Article A120) from June 1 to June 15 from 4,500 cfs to 6,500 cfs. If this AMM is enacted, and if the NRF is \leq 6,500 cfs, the Minimum Flow below the Turners Falls Dam shall be 67% of the NRF, subject to the conditions in Article A330. If this AMM is enacted, and if the NRF is $>$ 6,500 cfs, the Minimum Flow below the Turners Falls Dam shall be 4,290 cfs, subject to the conditions in Article A330.

³The magnitude of the Minimum Flow below Turners Falls Dam from June 1 to June 30 may be modified in the future pending fish passage effectiveness studies (see Article A330). If the Licensee conducts fish passage effectiveness studies, in consultation with the Massachusetts Division of Fisheries and Wildlife (MDFW), National Marine Fisheries Service (NMFS), and United States Fish and Wildlife Service (USFWS) and determines that migratory fish are not delayed by passing a greater percentage of the Total Minimum Bypass below Station No. 1 (see Article A120) via Station No. 1 discharges, the Licensee may file for a license amendment to increase the Station No. 1 discharge upon written concurrence of MDFW, NMFS, and USFWS. Prior to filing for a license amendment with the Commission, the Licensee shall consult the Massachusetts Department of Environmental Protection (MDEP) and address any of its comments in the license amendment filing.

Definition of Naturally Routed Flow

From December 1 through June 30, the NRF is defined as the hourly sum of the discharges from 12 hours previous as reported by the: Vernon Hydroelectric Project (FERC No. 1904), Ashuelot River United States Geological Survey gauge (USGS, Gauge No. 01161000), and Millers River USGS gauge (Gauge No. 01166500).

From July 1 through November 30, the NRF is defined as the hourly sum of the discharges averaged from 1 to 12 hours previous as reported by the: Vernon Hydroelectric Project, Ashuelot River USGS gauge, and Millers River USGS gauge. Upon license issuance until 3 years thereafter, the Licensee shall operate the Turners Falls Project based on the NRF computational method from July 1 through November 30 to determine if the Turners Falls Project can be operated in this manner. If the Turners Falls Project cannot be operated in this manner, the Licensee shall consult MDFW, NMFS, and USFWS on alternative means of computing the NRF that are feasible for Turners Falls Project operation and sufficiently dampen upstream hydroelectric project flexible operations.

The Minimum Flow below Turners Falls Dam may be temporarily modified if required by equipment malfunction or operating emergencies reasonably beyond the control of the Licensee. If the Minimum Flow below Turners Falls Dam is so modified, the Licensee shall notify the Commission, MDEP, MDFW, NMFS, and USFWS as soon as possible, but no later than 10 days after such incident. The Minimum Flow below Turners Falls Dam may also be temporarily modified for short periods upon mutual agreement with the Licensee for the Northfield Mountain Pumped Storage Project (FERC No. 2485), MDEP, MDFW, NMFS and USFWS, and upon 5 days' notice to the Commission.

Article A120. Total Minimum Bypass Flows below Station No. 1

Upon license issuance, the Licensee shall maintain the Total Minimum Bypass Flows below Station No. 1 as follows:

Appendix A: Draft License Articles- Turners Falls Hydroelectric Project

Article A100. Station No. 1 Upgrades

Within 3 years of license issuance, the Licensee shall automate Station No. 1 such that it is capable of being operated remotely and over a range of flows. The Licensee shall submit design plans to the Commission for automating Station No. 1. Upon Commission approval, the Licensee shall automate Station No. 1, including any changes required by the Commission.

Article A110. Minimum Flows below Turners Falls Dam

Upon license issuance, the Licensee shall discharge from the Turners Falls Dam or from the gate located on the power canal ("canal gate") just below the Turners Falls Dam the following seasonal minimum flows.

Date	Minimum Flows below Turners Falls Dam
01/01-03/31 ¹	<ul style="list-style-type: none">• If the Naturally Routed Flow (NRF- definition provided later in this article) is ≤ 400 cubic feet per second (cfs), the Minimum Flow below Turners Falls Dam shall be 400 cfs or the NRF, whichever is less.• If the NRF is > 400 cfs, the Minimum Flow below Turners Falls Dam shall be 400 cfs.
04/01-05/31	<ul style="list-style-type: none">• If the NRF is $\leq 6,500$ cfs, the Minimum Flow below Turners Falls Dam shall be 67% of the NRF.• If the NRF is $> 6,500$, the Minimum Flow below Turners Falls Dam shall be 4,290 cfs.
06/01-06/15 ^{2,3}	<ul style="list-style-type: none">• If the NRF is $\leq 4,500$ cfs, the Minimum Flow below Turners Falls Dam shall be 67% of the NRF.• If the NRF is $> 4,500$ cfs, the Minimum Flow below Turners Falls Dam shall be 2,990 cfs.
06/16-06/30 ³	<ul style="list-style-type: none">• If the NRF is $\leq 3,500$ cfs, the Minimum Flow below Turners Falls Dam shall be 67% of the NRF.• If the NRF is $> 3,500$ cfs, the Minimum Flow below Turners Falls Dam shall be 2,280 cfs.
07/01-11/15 ¹	<ul style="list-style-type: none">• If the NRF is ≤ 500 cfs, the Minimum Flow below Turners Falls Dam shall be 500 cfs or the NRF, whichever is less.• If the NRF is > 500 cfs, the Minimum Flow below Turners Falls Dam shall be 500 cfs.
11/16-12/31 ¹	<ul style="list-style-type: none">• If the NRF is ≤ 400 cfs, the Minimum Flow below Turners Falls Dam shall be 400 cfs or the NRF, whichever is less.• If the NRF is > 400 cfs, the Minimum Flow below Turners Falls Dam shall be 400 cfs.

Not draft
W.L.D.
 ≤ 250
150 now
in summer

¹From November 16 through March 31, the 400 cfs minimum flow below Turners Falls Dam will be provided from the canal gate, having a design maximum capacity of 400 cfs. The Licensee shall open the canal gate to its maximum opening and implement ice mitigation measures, if necessary, to maintain the maximum opening. The Licensee shall monitor canal gate operations to determine if supplemental measures, such as cable-heating the gate, are needed to maintain flows at or as close to 400 cfs as possible.

BACKGROUND

The purpose of this plan is to guide the Licensee's management and maintenance of lands at the Turners Falls Hydroelectric Project (Project) over the new license term for the protection of bald eagles.

Although bald eagles have been removed from the endangered species list, bald and golden eagles are still protected under multiple federal laws and regulations including the Bald and Golden Eagle Protection Act and the Migratory Bird Treaty Act.

Bald eagles winter along the Connecticut River in the Project area. Bald eagles are known to perch in riverbank trees and forage over the Connecticut River in Project vicinity. As part of licensing, several bald eagles, adults and juveniles, have been observed perching or foraging in the Turners Falls Impoundment (TFI) and Northfield Mountain in both 2014 and 2015, and three occupied bald eagle nests were located within the study area. These nests were found downstream on Third Island (below Cabot Station), near Smead Island, Barton Island in Barton Cove, and along the east bank of the TFI across from Stebbins Island in the upper reaches of the TFI. Since the study, the Licensees staff at the Northfield Mountain Visitor Center have provided anecdotal information on two additional eagle nests located within the TFI. One is located in the vicinity of Kidd's Island either on the Island or the eastern shore in the Town of Northfield and one in Turners Falls, on the hillside in the general vicinity of the Turners Falls Airport runway.

PROTECTION MEASURES

Given the nature and scope of Project operations, no adverse effects on bald eagles are anticipated. In the event that tree removal or construction activities are necessary at the Project, the Licensee shall implement the conservation measures described below to avoid effects to bald eagles.

Prior to any tree clearing within the Project boundary or areas immediately adjacent to the Project boundary by the Licensee or its contractors, the area to be cleared will be observed for bald eagle nests by the Licensee. If practicable, the Licensee should also survey for nests within 660 feet of the proposed clearing because nests adjacent to clearing may also be indirectly affected. If such nests are discovered, the Licensee shall consult the Massachusetts Division of Fisheries and Wildlife (MDFW) and the United States Fish and Wildlife Service (USFWS) prior to tree-clearing activities and the tree-clearing activities shall be performed in accordance with the applicable regulations and guidance (i.e., the National Bald Eagle Management Guidelines, USFWS 2007, or as amended).

During the nesting season (January 1 through September 30), no tree clearing will occur within 330 feet of, and no construction activities will occur within 660 feet of, any known bald eagle nests by the Licensee or its contractors. The National Bald Eagle Management Guidelines advise against conducting external construction and land clearing activities within 660 feet of bald eagle nests during the breeding season. Additionally, the Guidelines recommend maintaining a year-round buffer between nests and tree clearing of at least 330 feet and a year-round buffer between external construction and nests of either 330 or 660 feet, depending on the construction's size, visibility, and local precedence. For any project-related construction activities, work that requires blasting or other activities that produce extremely loud noises within 1/2 mile of active nests will be avoided. The Licensee shall consult with the MDFW and USFWS regarding tree clearing or construction activities that cannot meet these conditions.

Appendix B. Protection, Mitigation, and Enhancement Measures Recommended to be Included in the New Northfield Mountain Pumped Storage Project License

Appendix B: Draft License Articles- Northfield Mountain Pumped Storage Project

Article B100. Project Operations

Upon license issuance, the Licensee shall:

- (a) operate the Northfield Mountain Pumped Storage Project in accordance with its existing agreement with the United States Army Corps of Engineers (USACE). This agreement, memorialized in the Reservoir and River Flow Management Procedures (1976), as it may be amended from time to time, governs how the Project will operate during flood conditions and coordinate its operations with the Licensee of the Turners Falls Hydroelectric Project (FERC No. 1889).
- (b) operate the Northfield Mountain Pumped Storage Project upper reservoir between elevation 1004.5 and 920.0 feet National Geodetic Vertical Datum of 1929 (NGVD29).

Article B200. Fish Intake Protection and Consultation

Intake Protection

The Licensee shall install a barrier net in front of the Northfield Mountain tailrace/intake, having 3/8-inch mesh on the top and 1/4-inch mesh on the bottom. The barrier net design shall be based on the conceptual design in the Amended Final License Application filed with the Commission in December 2020, as modified through consultation with MDFW, NMFS, and USFWS, from June 1 to November 15 to protect out-migrating American Shad and adult American Eel, to be operational no later than June 1 of Year 7 after license issuance.

Consultation

The Licensee shall consult and obtain approval from MDFW, NMFS, and USFWS on the barrier net design and on operation and maintenance procedures. The Licensee shall consult MDFW, NMFS, and USFWS at the 30%, 60%, 90% and 100% design plan milestones. The Licensee shall file the 100% design plans with the Commission, along with documentation of consultation with MDFW, NMFS, and USFWS.

The Commission reserves the right to require changes to the design plans. Implementation of the design plans must not begin until the Licensee is notified by the Commission that the design plans are approved. Upon Commission approval, the Licensee shall implement the design plans, including any changes required by the Commission.

Article B210. Initial Intake Protection Effectiveness Testing and Fish Passage Performance Goals

Initial Effectiveness Testing

The Licensee shall complete construction of the Northfield Mountain barrier net, operate the barrier net for one season (shakedown year), and conduct representative and quantitative effectiveness testing in Years 10 and 11 to evaluate the downstream fish passage survival and time-to-pass compared to the performance goals below.

Consultation Process on Effectiveness Study Plans

For any initial fish passage effectiveness studies and any subsequent fish passage effectiveness studies required after implementing any AMMs described in Article B220, the Licensee shall provide the effectiveness study plans to MDFW, NMFS, and USFWS and request comments on the study plans within

30 days. The Licensee shall consult MDFW, NMFS, and USFWS and obtain their approval on the study plans before conducting the effectiveness study. The Licensee shall file the effectiveness study plans with the Commission, along with any consultation records.

Fish Passage Performance Goals

The Licensee shall compare the effectiveness study results to the following fish passage performance goals:

- 95% of juvenile American Shad arriving 500 meters upstream of the Northfield Mountain Pumped Storage Project tailrace survive migration past the Northfield Mountain Pumped Storage Project tailrace within 24 hours.
- 95% of adult American Shad arriving 1 kilometer upstream of the Northfield Mountain Pumped Storage Project tailrace survive migration past the Northfield Mountain Pumped Storage Project tailrace within 24 hours.
- 95% of American Eel arriving 1 kilometer upstream of the Northfield Mountain Pumped Storage Project tailrace survive migration past the Northfield Mountain Pumped Storage Project tailrace within 48 hours of a flow event. The definition of what constitutes a flow event shall be determined by the Licensee in consultation with MDFW, NMFS, and USFWS during effectiveness study plan development.

Article B220. Downstream Fish Passage- Initial Effectiveness Studies, Adaptive Management Measures and Subsequent Effectiveness Studies

Initial Effectiveness Studies- Years 10 and 11

The Licensee shall conduct initial effectiveness testing in Years 10 and 11 (Article B210) to evaluate the fish passage survival and time-to-pass of the newly constructed barrier net and compare the findings to the performance goals in Article B210. The Licensee shall develop a report by February 1 of Years 11 and 12 for adult American Shad and by April 1 of Years 11 and 12 for juvenile American Shad and adult American Eel summarizing the survival study findings and provide it to MDFW, NMFS, and USFWS. The Licensee shall consult MDFW, NMFS, and USFWS on the effectiveness study results and determine what, if any, adaptive managements measures (AMMs) may be implemented from the table below. The Licensee shall file a report with the Commission to include the effectiveness testing report and documentation of any AMMs agreed to by the Licensee, MDFW, NMFS, and USFWS, along with any consultation records. If warranted, the Licensee shall consult MDFW, NMFS and USFWS on when to implement any Round 1 AMMs.

Effectiveness Testing of Round 1 AMMs - Years 14 and 15

The Licensee shall conduct Round 1 AMM effectiveness testing in Years 14 and 15. The Licensee shall:

- Compare the effectiveness study results to the performance goals in Article B210.
- Provide the effectiveness study report to MDFW, NMFS, and USFWS by February 1 of Years 15 and 16 for adult American Shad and by April 1 of Years 15 and 16 for juvenile American Shad and adult American Eel.
- Consult MDFW, NMFS, and USFWS to determine what, if any AMMs may be implemented from the table below.
- File the effectiveness study report and documentation of any AMMs with the Commission.

If warranted, the Licensee shall consult MDFW, NMFS and USFWS on when to implement any Round 2 AMMs.

Effectiveness Testing of Round 2 AMMs - Years 17 and 18

The Licensee shall conduct Round 2 AMM effectiveness testing in Years 17 and 18. The Licensee shall follow the same consultations steps bulleted above; however, the Licensee shall provide the effectiveness study report to MDFW, NMFS, and USFWS by February 1 of Years 18 and 19 for adult American Shad and by April 1 of Years 18 and 19 for juvenile American Shad and adult American Eel.

MDFW, NMFS, and USFWS have agreed, consistent with the terms of the Flows and Fish Passage Settlement Agreement (March 2023), not to exercise any reserved or other regulatory authority regarding passage to request or require any AMMs other than those listed in the table below for the first 25 years of the license. In addition, they have agreed, consistent with the settlement agreement, not to request or require pumping restrictions at any time over the life of the license.

Downstream Adaptive Management Measures	
Adaptive Management Measure (if needed)	Timing
<u>Northfield Mountain Intake/Tailrace</u> <ul style="list-style-type: none">Alter the arrangement and size of the net panels (e.g. extend depth of the smaller panels).Improve maintenance measures for the net.	Initial Effectiveness Testing of Barrier Net: Years 10-11. Round 1 AMM Effectiveness Testing (if needed): Years 14-15 Round 2 AMM Effectiveness Testing (if needed): Years 17-18

Article B230. Fishway Operating Periods¹

The Licensee shall operate the barrier net for downstream passage from June 1 to November 15.

¹Future refinement of the timing may be made by the MDFW, NMFS, and USFWS based on new information and after consultation with the Licensee.

Article B240. Fish Passage Facility Operation and Maintenance Plan for Barrier Net

The Licensee shall develop and implement a Fish Passage Facilities Operations and Maintenance Plan (FOMP) for the barrier net. The FOMP shall detail how and when the barrier net will be operated and describe routine maintenance activities that will occur both during and outside of the downstream fish passage season. The FOMP will include a provision to provide annual fishway Operation and Maintenance (O&M) reports that summarize the status of the barrier net, identify needed repairs or equipment replacement, etc. The O&M report shall be submitted to the MDFW, NMFS, and USFWS by January 31 annually. The FOMP shall be developed in consultation with and require approval by the MDFW, NMFS, and USFWS prior to submitting the final FOMP to the FERC for approval.

The FOMP shall be completed no later than 6 months prior to the barrier net being placed into service, as outlined in the schedule in Article B200. Thereafter, the same FOMP shall be amended by the Licensee within 6 months prior to the following:

- Any AMM's are placed into service, as outlined in Articles B220; and,
- Any operational or facility modifications resulting from new information obtained from operation of the barrier net pursuant to the annual O&M reports.

Article B300. Bald Eagle Protection Plan

The Licensee shall implement the Bald Eagle Protection Plan dated January 2023.

Article B310. Bat Protection Measures

The Licensee shall implement the following measures to protect state or federally listed bat habitat: (1) avoid cutting trees equal to or greater than 3 inches in diameter at breast height within the Northfield Mountain Pumped Storage Project boundary from April 1 through October 31, unless they pose an immediate threat to human life or property (hazard trees); and (2) where non-hazard trees need to be removed, only remove non-hazard trees between November 1 and March 31.

**Northfield Mountain Project
(FERC Project Number 2485)**

Bald Eagle Protection Plan



JANUARY 2023

BACKGROUND

The purpose of this plan is to guide the Licensee's management and maintenance of lands at the Northfield Mountain Pumped Storage Project (Project) over the new license term for the protection of bald eagles.

Although bald eagles have been removed from the endangered species list, bald and golden eagles are still protected under multiple federal laws and regulations including the Bald and Golden Eagle Protection Act and the Migratory Bird Treaty Act.

Bald eagles winter along the Connecticut River in the Project area. Bald eagles are known to perch in riverbank trees and forage over the Connecticut River in Project vicinity. As part of licensing, several bald eagles, adults and juveniles, have been observed perching or foraging in the Turners Falls Impoundment (TFI) and Northfield Mountain in both 2014 and 2015, and two occupied bald eagle nests were located within the study area. These nests were found downstream on Third Island (below Cabot Station), near Smead Island, Barton Island in Barton Cove, and along the east bank of the TFI across from Stebbins Island in the upper reaches of the TFI. Since the study, the Licensees staff at the Northfield Mountain Visitor Center have provided anecdotal information on two additional eagle nests located within the TFI. One is located in the vicinity of Kidd's Island either on the Island or the eastern shore in the Town of Northfield and one in Turners Falls, on the hillside in the general vicinity of the Turners Falls Airport runway.

PROTECTION MEASURES

Given the nature and scope of Project operations, no adverse effects on bald eagles are anticipated. In the event that tree removal or construction activities are necessary at the Project, the Licensee shall implement the conservation measures described below to avoid effects to bald eagles.

Prior to any tree clearing within the Project boundary or areas immediately adjacent to the Project boundary by the Licensee or its contractors, the area to be cleared will be observed for bald eagle nests by the Licensee. If practicable, the Licensee should also survey for nests within 660 feet of the proposed clearing because nests adjacent to clearing may also be indirectly affected. If such nests are discovered, the Licensee shall consult the Massachusetts Division of Fisheries and Wildlife (MDFW) and the United States Fish and Wildlife Service (USFWS) prior to tree-clearing activities and the tree-clearing activities shall be performed in accordance with the applicable regulations and guidance (i.e., the National Bald Eagle Management Guidelines, USFWS 2007, or as amended).

During the nesting season (January 1 through September 30), no tree clearing will occur within 330 feet of, and no construction activities will occur within 660 feet of, any known bald eagle nests by the Licensee or its contractors. The National Bald Eagle Management Guidelines advise against conducting external construction and land clearing activities within 660 feet of bald eagle nests during the breeding season. Additionally, the Guidelines recommend maintaining a year-round buffer between nests and tree clearing of at least 330 feet and a year-round buffer between external construction and nests of either 330 or 660 feet, depending on the construction's size, visibility, and local precedence. For any project-related construction activities, work that requires blasting or other activities that produce extremely loud noises within 1/2 mile of active nests will be avoided. The Licensee shall consult with the MDFW and USFWS regarding tree clearing or construction activities that cannot meet these conditions.

**Appendix C. Measures Agreed to Among the Parties But Not to be Included in
New Project License**

ENVIRONMENTAL

Section C101. Ichthyoplankton Mitigation Fund (Northfield Mountain Project)

The Licensee of the Northfield Mountain Pumped Storage Project (FERC No. 2485) shall provide funding for habitat improvement projects and/or alosine management activities to offset the potential loss of ichthyoplankton through entrainment at the Northfield Mountain Pumped Storage Project. The Licensee shall make payments to the United States Fish and Wildlife Service or its designee per the schedule below by February 1 of each identified year.

Year after License Issuance	Amount
1	\$112,800
13	\$35,000
15	\$220,000
20	\$90,000
25	\$110,000
30	\$294,000
35	\$125,000
40	\$132,481
45	\$177,000
Total	\$1,296,281

Section C102. Cobblestone Tiger Beetle Fund (Turners Falls Project)

The Licensee of the Turners Falls Project (FERC No. 1889) shall provide funding for Cobblestone Tiger Beetle (CTB) conservation and management activities to provide a long-term net benefit to CTB in Massachusetts. The Licensee shall make payments to the Massachusetts Division of Fisheries and Wildlife or its designee per the schedule below by February 1 of each identified year.

Year after License Issuance	Amount
4	\$50,000
5	\$80,000
6	\$100,000
7	\$150,000
8	\$150,000
9	\$150,000
10	\$150,000
11	\$75,000
12	\$75,000
Total	\$980,000

OPERATIONS

Section C103. Agency Support for Flow Data from Licensee of Vernon Hydroelectric Project (Turners Falls and Northfield Mountain Projects)

The Massachusetts Division of Fisheries and Wildlife (MDFW) shall independently request from the Commission, at the same time the Settlement Agreement is filed, that the Licensee of the Vernon Hydroelectric Project (Vernon Project, FERC No. 1904) shall provide to the Licensees of the Turners Falls Hydroelectric Project (FERC No. 1889) and Northfield Mountain Pumped Storage Project (FERC No. 2485) the following upon license issuance:

- Electronically provide by 8:00 am of each day, the next day's 24 hour anticipated Vernon Project total discharge. The next day's 24-hour anticipated Vernon Project total discharge will be updated once the day ahead power bidding market closes and Independent System Operator-New England (ISO-NE) issues the day ahead schedule. If ISO-NE updates the day ahead hourly Vernon Project total discharge, then that revised schedule shall be provided to the Licensees within 2 hours of the Vernon Project Licensee receiving an update from ISO-NE.
- Electronically provide the instantaneous Vernon Hydroelectric Project total discharge and tailwater elevation.

Section C104. Licensee Reporting on Flow Stabilization below Cabot Station Measures for Years 1 -3 after License Issuance (Turners Falls Project)

Upon license issuance, the Licensee shall implement the proposed Flow Stabilization below Cabot Station as defined in Article A160. *Flow Stabilization below Cabot Station and Allowable Deviations for Flexible Operations*¹, recognizing that it will not be required to demonstrate to the Federal Energy Regulatory Commission (FERC), or the Parties, that it is meeting the Flow Stabilization below Cabot Station requirements until the third (3rd) anniversary of the date of license issuance. The Licensee shall provide the Parties an annual report (by March 1 of the following year) for Years 1 and 2 and quarterly reports for Year 3 to demonstrate substantive progress towards implementing the Flow Stabilization below Cabot Station. Quarterly reports for January 1 to March 31, April 1 to June 30, July 1 to September 30 and October 1 to December 31 shall be provided to the Parties by June 1, September 1, December 1 and March 1 (of the following year), respectively.

¹The Flow Stabilization below Cabot Station is based on providing a percentage of the naturally routed flow (NRF). The NRF is defined in Article A110. *Minimum Flows below Turners Falls Dam* as follows:

From December 1 through June 30, the NRF is defined as the hourly sum of the discharges from 12 hours previous as reported by the: Vernon Hydroelectric Project (FERC No. 1904), Ashuelot River United States Geological Survey gauge (USGS, Gauge No. 01161000), and Millers River USGS gauge (Gauge No. 01166500).

From July 1 through November 30, the NRF is defined as the hourly sum of the discharges averaged from 1 to 12 hours previous as reported by the: Vernon Hydroelectric Project, Ashuelot River USGS gauge, and Millers River USGS gauge. Upon license issuance until 3 years thereafter, the Licensee shall operate the Turners Falls Project based on the NRF computational method from July 1 through November 30 to determine if the Turners Falls Project can be operated in this manner. If the Turners Falls Project cannot

be operated in this manner, the Licensee shall consult Massachusetts Division of Fisheries and Wildlife, National Marine Fisheries Service and United States Fish and Wildlife Service on alternative means of computing the NRF that are feasible for Turners Falls Project operation and sufficiently dampen upstream hydroelectric project flexible operations.

FirstLight

Justin Trudell
Chief Operating Officer
FirstLight Power
111 Soth Bedford Street, Suite 103
Burlington, MA 01803
Phone: 781-653-4247
Email: justin.trudell@firstlightpower.com

American Whitewater

Bob Nasdor
Northeast Stewardship & Legal Director
American Whitewater
65 Blueberry Hill Lane
Sudbury, MA 01776
Phone: 617-584-4566
Email: bob@americanwhitewater.org

Appalachian Mountain Club

Mark Zakutansky
Director of Conservation Policy Engagement
Appalachian Mountain Club
45 Jordan Road, PO Box 527
Albrightsville, PA 18210
Phone: 610-868-6915
Email: mzakutansky@outdoors.org

Crab Apple Whitewater, Inc.

Frank Mooney
River Manager/Ownership Family
Crab Apple Whitewater, Inc.
PO Box 295
Charlemont, MA 01339
Phone: 413-824-1842
Email: frank@crabapplewhitewater.com

Appendix D. Authorized Representatives of the Parties

Massachusetts Division of Fisheries and Wildlife

Todd Richards
Assistant Director of Fisheries
Massachusetts Division of Fisheries and Wildlife
1 Rabbit Hill Road
Westborough, MA 01581
Phone: 508-389-6336
Email: todd.richards@mass.gov

Everose Schluter
Assistant Director of Natural Heritage & Endangered Species Program
Massachusetts Division of Fisheries and Wildlife
1 Rabbit Hill Road
Westborough, MA 01581
Phone: 508-389-6346
Email: eve.schluter@mass.gov

National Marine Fisheries Service

Christopher Boelke
Chief, New England Branch
Habitat and Ecosystem Services Division
NOAA Fisheries, Greater Atlantic Regional Fisheries Office
55 Great Republic Drive
Gloucester, MA 01930
Phone: 978-281-9131
Email: christopher.boelke@noaa.gov

New England Flow

Tom Christopher
New England FLOW
240 Fort Pond Road
Lancaster, MA 01523
Phone: 508-331-4889
Email: tom.christopher@comcast.net

The Nature Conservancy

Katie Kennedy
Applied River Scientist
North America Region
The Nature Conservancy
PO Box 32
Chesterfield, MA 01012
Phone: 413-588-1959
Email: kkennedy@tnc.org

United States Fish and Wildlife Service

Supervisor
New England Field Office
U.S. Fish and Wildlife Service
70 Commercial Street, Suite 300
Concord, NH 03301-5087
Phone: 603-223-2541
Email: newengland@fws.gov

Zoar Outdoor

Janet Cowie
Zoar Outdoor
PO Box 245
Charlemont, MA 01339
Phone: 413-339-4010
Email: janet@zoaroutdoor.com

CERTIFICATE OF SERVICE

I hereby certify that I have this day served the foregoing document upon each person designated on the official service list compiled by the Federal Energy Regulatory Commission in these proceedings.

Dated at Washington, DC this 31st day of March, 2023.

/s/ Mealear Tauch

Mealear Tauch
Van Ness Feldman, LLP
1050 Thomas Jefferson Street, NW
Seventh Floor
Washington, DC 20007-3877